

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1527:101 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: National Time & Signal Corporation, 28045 Oakland Oaks Court, Wixom, MI 48393-3342
Contact: Leo Mullins (248) 380-6264 *Fax (248) 380-6268

DESIGN: Model 902-RPS and 902-RPS-240 Power Boosters. Unit comprises of an enclosure, transformer and printed circuit board. The printed circuit board employs two notification appliances circuits, one auxiliary output circuit and two initiating input circuit which accepts either a notification appliance circuit from a fire alarm control unit or dry contact output. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL label.

APPROVAL: Listed as power boosters for use with separately listed compatible fire alarm control units.

NOTE: Units must provide at least 24 hours battery standby power during power loss. The battery circuit must be fully supervised.

*Rev. 08-20-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager